



NOTES:

1. REFER TO STD DRG S1-2-3-4 FOR EARTHING ARRANGEMENT, DETAILS AND MATERIALS
2. POWER FASTENERS TO BE PLACED AT MAX 1000 CENTRES.

TAG NO	QTY	DESCRIPTION	STOCK CODE	DRG REF
6	AR	POWER FASTENERS (EG RAMSET)	-	-
5	3	BOLT M10 X 40LG C/W NUT FLAT. AND SPR WASHER	-	-
4	2	LUG COPPER COMPRESSION - 19/2.14 70sq.mm	5512	-
3	AR	CONDUCTOR - Cu 19/2.14	9803	S1-1-5-5
2	AR	BUSBAR - Cu 25 X 3mm	9837	S1-1-5-5
1	AR	BUSBAR EARTHING - Cu 25 X 4mm	3020	S1-1-5-6

DES	B. KENT	POWER STANDARD DRAWING		
DRN	PMC			
CKD	g.mck			
APPD	B. KENT			
SCALE	N.T.S.			
ISSUED	SEPT'89	A3	DRAWING NUMBER	S4-2-3-2
ALL DIM.	IN mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMMEND MANUALLY		



NO	DESCRIPTION	DRN	DATE	CKD	APPD
2	ITEM 4 Q/LUG CHANGED TO COMPRESSION CHANGES TO NOTES.	K. I. R. G. I.	FEB'05	C. C. A. G. B.	C. C. F. R. R.
1			FEB'97		
AMENDMENTS					

