



NOTES:

1. ALL WORKMANSHIP AND MATERIALS SHALL BE IN ACCORDANCE WITH AS 3678.
2. ALL WELDING AND WELD PREPARATION SHALL BE IN ACCORDANCE WITH AS 1554. FILLET WELDS TO BE 6mm UNO.
3. ALL ROUGH OR BURRED EDGES ARE TO BE DRESSED CLEAN.
4. BOLTS TO BE METRIC, PROPERTY CLASS 4.6 AND SHALL BE IN ACCORDANCE WITH AS 1111.

						DES	B. KENT	POWER STANDARD DRAWING	
						DRN	PWG	POLE STRUCTURES, LV - ABC	
					CKD	g. mck	SUBSTATION POLE		
					APPD	B. KENT	CONSTRUCTION DETAILS		
					SCALE	N.T.S.	A3	DRAWING NUMBER	S4-2-5-1
					ISSUED	SEPT '89			
					ALL DIM.	IN mm			
					DRAFTING STANDARD TO A.S. 1100		CAD PRODUCT - DO NOT AMEND MANUALLY		
1	NOTE 1. AUSTRALIAN STANDARD CHANGED.				RG1	FEB '97	A.B.	F.R.R.	
NO	DESCRIPTION				DRN	DATE	CKD	APPD	
AMENDMENTS									