



REFER TO DRAWING
No. S1-2-3-4 FOR
EARTHING ARRANGEMENT
T.P. AND C.T.P.

NOTES

1. FOR CABLE TERMINATIONS REFER DRAWINGS :
- S4-2-4-2 FOR 100kVA SUBSTATION
 - S4-2-4-3 FOR 200kVA SUBSTATION
 - S4-2-4-4 FOR 300kVA SUBSTATION

8	AR	Cu 70sqmm LV FLEXIBLE	406718	S2-1-1-34
7	3	CONNECTION TYPE 'CU'	5603	S1-2-1-1
6	AR	CABLE - 70sqmm Cu LV XLPE	406733	-
5	3	CONNECTION TYPE 'TLA'	2196	-
4	3	SURGE DIVERTER - HV	10033	S1-1-4-19
3	1	HV EDO CROSSARM UNIT	-	-
2	1	HV CROSSARM UNIT	-	S1-2-5-5
1	1	POLE STRUCTURE	-	S4-2-5-1

TAG No	QTY	DESCRIPTION	STOCK CODE	DRG REF
--------	-----	-------------	------------	---------

MATERIAL SCHEDULE

NO	DESCRIPTION	DRN	DATE	CKD	APPD
1	ITEM 6 AND ITEM 8 AMENDED	A.S.	NOV'06	R.S.	S.C.
AMENDMENTS					



DES	B.T. KENT	POWER STANDARD DRAWING		
DRN	gmck	SUBSTATIONS LV - ABC SINGLE POLE		
CKD	T.M-L			
APPD	B.T. KENT			
SCALE	N.T.S.			
ISSUED	SEP'89	A3	DRAWING NUMBER	S4-2-6-1
ALL DIM.	IN mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY		 AMDT