


METER SOCKET - 3 JAW
(EMAIL CAT. No. 828140)

NOT FOR NEW CONSTRUCTION

PowerWater	1	NOT FOR NEW CONSTRUCTION	C.M.	11.1.13	B.N.	DES DRN A.SCHMID	FIG.22 - COMPONENT DRILLING DETAILS METER SOCKET	A4	DRAWING NUMBER S11-2-7-23	 AMDT	
	A	ISSUED FOR COMMENT	A.S.	18.1.02		CKD					
	NO	DESCRIPTION	DRN	DATE	APPD	APPD					SCALE 1:2
	AMENDMENTS					ALL DIM. IN mm					DRAFTING STANDARD TO A.S.1100

NOTE :

PANEL AREA REQUIRED

MIN. WIDTH 175mm

MIN. HEIGHT 280mm

TYPICAL
SINGLE PHASE METER

20



11

22

22

22

DRILL 4 HOLES $\phi 12$ IN METER
PANEL FOR CABLE ACCESS

	0	APPROVED FOR INSTALLATION	R.W.	4.9.09	N.C.	DES N.COAD	FIG.22b SINGLE PHASE kWh METER DRILLING DETAILS FOR CABLE ACCESS SHEET 2
	A	ISSUED FOR COMMENT	R.W.	4.9.09	N.C.	DRN R.WILLIAMS	
	NO	DESCRIPTION	DRN	DATE	APPD	CKD N.COAD	
	AMENDMENTS					APPD B.KISON	
						ALL DIM. IN mm	A4 DRAWING NUMBER S11-2-7-23
						DRAFTING STANDARD TO A.S.1100	CAD PRODUCT — DO NOT AMEND MANUALLY 

NOTE :

PANEL AREA REQUIRED

MIN. WIDTH 180mm

MIN. HEIGHT 330mm


TYPICAL
POLYPHASE
WHOLE CURRENT METER

20

7

18 18 18 18 18 18 18

DRILL 8 HOLES $\phi 12$ IN METER
PANEL FOR CABLE ACCESS

	0	APPROVED FOR INSTALLATION	R.W.	4.9.09	N.C.	DES N.COAD	FIG.22C POLYPHASE WHOLE CURRENT METER DRILLING DETAILS FOR CABLE ACCESS SHEET 3
	A	ISSUED FOR COMMENT	R.W.	4.9.09	N.C.	DRN R.WILLIAMS	
						CKD N.COAD	
						APPD B.KISON	
	NO	DESCRIPTION	DRN	DATE	APPD	SCALE 1:5	A4 DRAWING NUMBER S11-2-7-23
AMENDMENTS						ALL DIM. IN mm	
						DRAFTING STANDARD TO A.S.1100	CAD PRODUCT — DO NOT AMEND MANUALLY

