



CUBICLE SHALL BE PROVIDED WITH :

1. C20/40 RAILS FOR MOUNTING OF C.T.'s AND ESCUTCHEON.
2. C.T. MOUNTING COMPLETE WITH REMOVEABLE BUSBAR & BUSBAR MOUNTING BLOCKS. ESCUTCHEON SHALL BE SEALABLE.
3. METAL SHIELDING BETWEEN METER AND INCOMING CONDUCTORS.
4. HINGED METER PANEL MINIMUM SIZE 500 x 500mm.
5. HINGED ESCUTCHEON PANEL.
6. PLINTH.
7. CUBICLE TO BE SIMILAR TO B AND R TYPE SMBI/20.

				 POWER AND WATER AUTHORITY NORTHERN TERRITORY		DES	FIG.28 - STANDARD C.T. METERING CUBICLE	
						DRN		
				CKD				
				APPD				
				SCALE	N.T.S.			
				ISSUED		A4	DRAWING NUMBER	S11-2-7-29
				ALL DIM. IN mm				
				DRAFTING STANDARD TO A.S.1100		CAD PRODUCT — DO NOT AMEND MANUALLY		 AMDT
A	ISSUED FOR COMMENT	A.S.	24.3.02					
NO	DESCRIPTION	DRN	DATE	APPD				
AMENDMENTS								