


CUBICLE SHALL BE PROVIDED WITH :

1. C20/40 RAILS FOR MOUNTING OF C.T.'s AND ESCUTCHEON.
2. C.T. MOUNTING COMPLETE WITH REMOVEABLE BUSBAR & BUSBAR MOUNTING BLOCKS. ESCUTCHEON SHALL BE SEALABLE.
3. METAL SHIELDING BETWEEN METER AND INCOMING CONDUCTORS.
4. HINGED METER PANEL MINIMUM SIZE 500 x 500mm.
5. FIXED ESCUTCHEON PANEL.
6. PLINTH.
7. CUBICLE TO BE SIMILAR TO B AND R TYPE SMBI/1.

						DES		FIG.29 - STANDARD C.T. METERING CUBICLE	
						DRN A.SCHMID			
				CKD		A4 DRAWING NUMBER S11-2-7-30			
				APPD					
				SCALE N.T.S.		ALL DIM. IN mm		DRAFTING STANDARD TO A.S.1100 CAD PRODUCT — DO NOT AMEND MANUALLY	
				ISSUED					
A	ISSUED FOR COMMENT	A.S.	24.3.02						
NO	DESCRIPTION	DRN	DATE	APPD					
AMENDMENTS									