



NOTES :

1. METER INSTALLED BY PWC.
2. POTENTIALS ORIGINATE ON LINE SIDE OF C.T.'s.
3. CONNECTIONS AS PER SECTION 7.4(f) or 7.7(d) OF METER MANUAL.
4. INSTALLATION AS PER METER MANUAL SECTION 7 : LV CT METERING.
5. THE MAIN SWITCH SHALL HAVE PROVISION FOR SEALING.

				DES	LOW VOLTAGE	
				DRN	A.SCHMID	
4				ADDED MAIN SWITCH & NOTE 5	CWM	20.11.12
3				UPDATED NOTES	CWM	29.6.12
2				RELOCATED FUSES	CWM	6.6.12
A				ISSUED FOR COMMENT	A.S.	24.3.02
NO				DESCRIPTION	DRN	DATE
AMENDMENTS				APPD	ALL DIM. IN mm	
PowerWater				ISSUED	A4	DRAWING NUMBER
						S11-2-7-42
						AMDT
						CAD PRODUCT — DO NOT AMEND MANUALLY

