



- NOTES :**
1. THE SOLAR SUPPLY ISOLATORS SHALL HAVE IN BUILT PROVISION TO BE LOCKABLE IN THE "OFF" POSITION.
 2. THE CIRCUIT BREAKERS SHALL HAVE IN BUILT LOCKING PROVISIONS TO BE LOCKABLE IN THE "OFF" POSITION.
 3. SINGLE PHASE SERVICE PADLOCKABLE CIRCUIT BREAKER WITH SEALABLE ENCLOSURE.
 4. LABELLING ON THE INSTALLATION AND SWITCHBOARD SHALL BE DONE AS PER THE SIGNAGE REQUIREMENTS MENTIONED IN THE PV DOCUMENTS No. 1 AND 2 NOTED.
 5. ALL CUSTOMERS WIRING AFTER LOAD SIDE OF THE METER POINT SHALL COMPLY TO AS3000 AT ALL TIMES AND AS3010 WITH A CHANGEOVER SWITCH WHEN ADDITIONAL GENERATION IS INSTALLED.

THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE FOLLOWING POWER AND WATER DOCUMENTS.

1. REQUIREMENTS FOR GRID CONNECTION OF PHOTOVOLTAIC SYSTEMS VIA INVERTERS
2. CHAPTER 10 OF THE METERING MANUAL: "SMALL SCALE PARALLEL CUSTOMER GENERATION (VIA INVERTERS)"

SCHEMATIC FOR TYPE - 2 SINGLE PHASE

NO	DESCRIPTION	DRN	DATE	CKD	APPD	DESIGNATION		DRAWING NUMBER	S11-2-7-49	AMDT
4	REMOVED PV METER AND NOTE 5 AMENDED	C.M.	MAR'15	A.T.	B.C.	DES	B.N.			
3	CHANGES IN NOTES	C.M.	JUL'12	B.N.	B.C.	DRN	C.M.			
2	CHANGES IN NOTES	C.M.	AUG'10	B.N.	B.C.	CKD	B.N.			
1	CHANGES IN NOTES	C.M.	JUL'10	B.N.	B.C.	APPD	B.C.			
0	APPROVED FOR INSTALLATION	C.M.	APR'10	B.N.	B.C.	SCALE	NTS			
A	ISSUED FOR COMMENT	C.M.	FEB'10	B.N.	B.C.	ISSUED	APR'10			
AMENDMENTS						PowerWater NORTHERN TERRITORY		4		